



Hopkinsville Water Environment Authority

ADDENDUM NO. 2
PYLE LANE SEWAGE PUMPING STATION REHABILITATION
HWEA Project SOW #21-2020-A
HOPKINSVILLE WATER ENVIRONMENT AUTHORITY
HOPKINSVILLE, KENTUCKY
Bid #2122-03

Date of Addendum: Thursday, September 2, 2021
Bid Opening: Thursday, September 16, 2021, 1:00 PM CST

1. Standard Specifications for Sewage Pumping Station and Related Appurtenances, Section 6. Submersible Pumps and Pumping Station Construction, Subsection C. Pump Characteristics:

The submersible pumps shall be provided by Flygt (Xylem) or an approved equal as determined by the Owner.

2. Standard Specifications for Sewage Pumping Station and Related Appurtenances, Section 6. Automatic Pump Control System, Subsection B. Pump Control Description:

The transient voltage surge protection device shall be a Flygt (Xylem) SPP Series or an approved equal as determined by the Owner.

3. Exhibit – I: Contractor Furnished and Installed – Xylem Products:

This exhibit now denotes a pump package pre-approved by Owner. Alternative pump packages must be comparable in installation, operation, and maintenance, and be submitted for review by the Owner.

Hopkinsville Water Environment Authority

A handwritten signature in black ink, appearing to read "David Blane", is written over a horizontal line.

David Blane
Director of Engineering, Construction, &
Distribution